



**CAUTION:**

This Sterile Conditioning System incorporates ultraviolet germicidal lamps. Care should be taken when operating and maintaining this equipment. Protect eyes and skin from ultraviolet rays. Disconnect power prior to servicing this unit. Allow 3-5 minutes for the lamps to cool.



Fuller Ultraviolet Corporation– Frankfort, IL.		Ph. 815-469-3301
Project: Sterile Conditioner Breakdown		dch:
Model: FG 2072	Power: 120 V. 50/60 Hz.	scale: none